
Facility A: On-shore, non-production facility with >1,320 gallons of aboveground storage or >42,000 gallons of underground storage of SPCC regulated oils.
UST
Potentially regulated under the following regulations: 40 CFR 112, 280, 281
Is my tank subject to the technical requirements in 40 CFR 280 (Federal UST Standards)?*
Yes
40 CFR 280 applies
*Cut and covered, partially buried, or bunkered aboveground storage tanks can be dually regulated by SPCC and the Federal UST Standards. This flow chart is not addressing these tanks.
No
Is my tank subject to the technical requirements in an approved program under 40 CFR 281 (State UST Regulations)?
Yes
Tank is either exempted/excluded from regulation or subject to state regulations.
40 CFR 281 exempts/excludes or applies
No
Tank is not exempted/excluded from regulation or subject to state regulations.
Is my tank subject to 40 CFR 112 (SPCC)?
Yes
Tanks that are not subject to the technical requirements under Federal or State regulations are regulated by SPCC.
40 CFR 112 applies